

## **2006 CHAPTER 69A-46 FIRE PROTECTION SYSTEM CONTRACTORS AND SYSTEMS**

### **PART I APPLICATION PROCEDURES**

69A-46.001 Scope.

69A-46.010 Submission of the Application.

69A-46.015 Testing.

69A-46.016 Insurance Requirements.

69A-46.017 Required Continuing Education.

### **PART II GENERAL PROVISIONS**

69A-46.025 Scope.

69A-46.030 Definitions.

69A-46.035 Standards of National Fire Protection Association to Be Complied With.

69A-46.040 Installation Requirements for Automatic Sprinkler Systems Employing Water as the Extinguishing Agent.

69A-46.041 Inspection, Testing and Maintenance Requirements for Fire Protection Systems.

### **PART I APPLICATION PROCEDURES**

#### **69A-46.001 Scope.**

The provisions of this part shall apply to those individuals wishing to be qualified by the State Fire Marshal as a contractor of fire

protection systems in this state pursuant to the provisions of Section 633.521, F.S.

*Specific Authority 633.01, 633.517(1) FS. Law Implemented 633.521, 633.524, 633.534 FS. History—New 10-14-86, Formerly 4A-46.001.*

#### **69A-46.010 Submission of the Application.**

(1) The applicant shall submit an application on a form furnished by the division which shall conform with Section 633.534,

F.S.

(2) The application shall be accompanied by a fee as prescribed in Section 633.524, F.S.

(3)(a) As a prerequisite to challenging the examination as a Contractor I, II, or III, the applicant shall provide evidence of four

(4) years proven experience in the employment of a Contractor I, II, or III, or a combination of experience and education equivalent

thereto.

1. "Experience in the employment of a contractor", as required by Section 633.521(3), F.S., must be gained from full-time

employment by a contractor, such employment relating to technical areas. For purposes of this rule chapter, "technical areas"

means those activities engaged in by a contractor and participated in by the applicant which provide experience in laying out,

fabricating, installing, inspecting, altering, repairing, or servicing fire protection systems. For purposes of this rule chapter, four (4)

years proven experience as a certified plumbing contractor, licensed pursuant to the provisions of Chapter 489, F.S., may be offered

toward the experience requirements for a Contractor I or II and shall be considered equivalent to two (2) years proven experience in

the employment of a contractor. A certified plumbing contractor shall offer no more than 4 years as a certified plumbing contractor

toward the 4 years experience requirement in Section 633.521, F.S. The applicant's experience must be verified by the contractor

employing the applicant. The required verification shall be in the form of a letter from the employer, on company stationery,

describing the applicant's duties, the kinds of jobs he worked on; his dates of employment; and any other information reasonably

calculated to provide the division with an informed understanding of the applicant's work experience. An applicant offering

self-employment experience shall provide verification in the form of letters from customers, and others familiar with his work. It is

the applicant's responsibility to furnish the required verification. The experience will be evaluated to determine an applicant's qualifications for the class of certificate requested; or,

2. The division will accept a current NICET Level III or IV certification as a Fire Protection Engineering Technician in the subfield of Automatic Sprinkler System Layout, for contractor I and II applicants, and will accept a current NICET Level III or IV certification as a Fire Protection Engineering Technician in the subfield of Special Hazards System Layout, for Contractor III applicants, issued by the National Institute for Certification in Engineering Technologies in Alexandria, Virginia; or,

3. The applicant can provide evidence of a combination of experience and education equivalent to four (4) years proven experience in the employment of a contractor. Acceptable education shall include, but not be limited to, a bachelor degree from a four (4) year college or university with a major in mechanical engineering, civil engineering, fire science engineering technology, or equivalent coursework; or an associate degree (2 years) with a major in fire science engineering technology or fire protection engineering technology. The applicant must furnish official transcripts to substantiate all degrees and coursework. The curriculum, degree, date degree awarded, and all engineering, fire science, and fire protection courses must be clearly identified on the transcripts. Acceptable experience to combine with the education offered shall be provided in the same form as required under subparagraph 1., above. For purposes of combining education and work experience, the number of hours worked in part-time employment will be counted as the appropriate percentage of full-time employment.

- 85

4.a. Applicants for certification as a Contractor I who are offering 4 years proven experience as a certified plumbing contractor as the equivalent of 2 years proven experience in the employment of a contractor shall combine that experience with a NICET Level III or IV certificate; or with 18 credit hours from a 4-year college or university, or a junior or community college in courses which teach the material in the National Fire Protection Association standards on which the applicant will be tested; or with other equivalent coursework.

b. Applicants for certification as a Contractor II who are offering 4 years proven experience as a certified plumbing contractor as the equivalent of 2 years proven experience in the employment of a contractor shall combine that experience with a NICET Level III or IV certificate; or with 15 credit hours from a 4-year college or university, or a junior or community college in courses which teach the material in the National Fire Protection Association standards on which the applicant will be tested; or with other equivalent coursework.

(b) As a prerequisite to challenging the examination as a Contractor IV, the applicant shall provide evidence of two (2) years proven experience in the employment of a Contractor I, II, or IV, or a combination of equivalent education and experience, which combination need not include experience in the employment of a contractor. For purposes of combining education and experience, education in the areas described in subparagraph (a)3., above, including at least 3 credit hours from a 4-year college or university or

junior or community college in courses which teach the material in the National Fire Protection Association standards on which the applicant will be tested; or other equivalent coursework; and experience in the areas described in subparagraph (a)1., above, shall be provided. In addition, the division will accept a current NICET Level III or IV Certification as a Fire Protection Engineering Technician in the subfield of Automatic Sprinkler System Layout, issued by the National Institute for Certification in Engineering Technologies in Alexandria, Virginia.

(c) As a prerequisite to challenging the examination as a Contractor V, the applicant shall provide evidence of:

1. Licensing as a certified underground utility contractor, pursuant to the provisions of Chapter 489, F.S., which shall be submitted in the form of a copy of the license issued by the Department of Business and Professional Regulation, accompanied by a statement that the applicant certifies that he is the person named on the license; or
2. Employment by an individual licensed as a certified underground utility contractor pursuant to the provisions of Chapter 489, F.S., that the applicant has four (4) years experience in the employment of a certified underground utility contractor, which shall be submitted in the form of a letter, on company stationery, signed by the certified underground utility contractor, describing the applicant's duties; the kinds of jobs he worked on; his dates of employment; and any other information reasonably calculated to provide the division with an informed understanding of the applicant's work experience; or
3. A combination of education and experience equivalent to four (4) years proven experience in the employment of a certified underground utility contractor. For purposes of combining education and experience, education in the areas described in paragraph (a)3., above, including at least 3 credit hours from a 4-year college or university or junior or community college in courses which teach the material in the National Fire Protection Association standards on which the applicant will be tested; or other equivalent coursework; and experience in the areas described in subparagraph (a)1., or subparagraph (c)1. or 2., above, shall be provided.

(d) For all classes of contractor applicants the division will accept other experience and education combinations which are equivalent to those described above.

(4) The applicant shall not be approved to challenge a competency examination unless the applicant has substantiated employment experience or a combination of employment and education. The applicant is encouraged to submit documentation of all relevant experience and education since each instance of a combination prerequisite must necessarily be decided individually.

When the review of the application has been completed the applicant will be notified in writing whether or not he has qualified to

challenge the competency examination in accordance with the provisions of Chapter 120, F.S.

*Specific Authority 633.01, 633.517(1) FS. Law Implemented 633.521, 633.524, 633.534 FS. History—New 10-14-86, Amended 12-21-88, 10-20-93, Formerly 4A-46.010.*

#### **69A-46.015 Testing.**

(1) An applicant who has been qualified to challenge an examination will be notified in writing of available examination dates and examination locations. Upon receipt of a written request for a specific examination date, the applicant will be sent a notice of

the exam date, time and location at least seven days prior to the scheduled exam. The applicant will be expected to challenge the exam on that day unless he or she submits a written waiver of his or her right to challenge the exam on that day and requests a later date. The Regulatory Licensing Section will schedule an applicant for a later day upon receipt of a written request. The applicant will also be permitted to challenge the examination at the Regulatory Licensing Section's office in Tallahassee if the applicant makes a request for such testing in writing and receives written notification when the next available scheduled examination will be held in Tallahassee.

(2) The examinations are multiple choice and open book. The examinations are based on relevant Florida and federal laws pertaining to the construction industry, safety standards, administrative procedures, pertinent technical data, and on standards of the National Fire Protection Association (NFPA). An applicant shall be notified of the study material required for the contractor class for which he has applied.

(3) Each applicant must provide his or her own NFPA standards and other resource materials for use during the exam.

Applicants will not be allowed to share standards or materials during an examination.

- 86

(4) NFPA standards may be obtained from the National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02215. Sources for other materials will be listed on the information sheet supplied to each applicant before the examination.

(5) The applicant must bring positive identification, including identification containing the applicant's photograph, to the exam.

(6) Examination grades and papers are confidential. Applicants will be notified of examination scores in writing only.

(7) Reexaminations will be scheduled no sooner than 30 days after any administration of an examination to an applicant. Each

examination scheduled requires an examination fee as provided in Section 633.524, F.S.

(8) Upon successful completion of a competency examination an applicant must submit evidence of insurance coverage meeting the requirements of Section 633.521, F.S.

(9) Upon satisfactory completion of the application, testing and insurance requirements, a certificate will be issued.

*Specific Authority 633.01, 633.517(1) FS. Law Implemented 633.521 FS. History--New 10-14-86, Amended 12-21-88, 8-1-90, 10-20-93, 10-2-96, 6-8-98, 11-21-01, Formerly 4A-46.015.*

**69A-46.016 Insurance Requirements.**

(1) The Fire Protection System Contractor I, II, III, IV, or V licensed pursuant to Section 633.521, F.S., shall provide evidence of current and subsisting insurance coverage meeting the requirements of Section 633.521, F.S., to the Regulatory Licensing Section on Form DI4A-25, Certificate of Insurance Fire Protection System Contractor, revised and dated 10/99, as adopted and incorporated herein by reference. This form is available from the Regulatory Licensing Section, Bureau of Fire Prevention, 200 East Gaines Street, Tallahassee, FL 32399-0342.

(2) The licensed Fire Protection System Contractor I, II, III, IV, or V shall be responsible to ensure that current and subsisting

insurance coverage meets the requirements of Section 633.521, F.S., and is on file with the Regulatory Licensing Section.

(3) Failure to provide evidence of insurance coverage within 30 days of the expiration date of the policy or within 30 days of a

notice to provide evidence of coverage shall result in administrative proceedings pursuant to Section 624.4211, F.S., as provided in

subsection (4) of Section 633.521, F.S.

*Specific Authority 633.01, 633.517(1), 633.521(4) FS. Law Implemented 633.521(4) FS. History--New 10-20-93, Amended 11-21-01, Formerly 4A-46.016.*

**69A-46.017 Required Continuing Education.**

(1) Certificateholders shall complete a continuing education course or combination of courses in compliance with Section

633.537, F.S., within each license period.

(2) The continuing education course or combination of courses shall be in a fire protection discipline related to the Certificate

of Competency held by the Fire Protection System Contractor. All licensed Fire Protection System Contractors are required to

complete at least one hour of workplace safety class, one hour of business practices class, and one hour of a workers' compensation

class as part of the required continuing education for each biennial renewal period.

(3) The course or combination of courses shall be conducted by persons approved by the Regulatory Licensing Section.

Approval of such persons shall be based on the person's training, experience and expertise in fire protection under Florida law. The

instructor must be qualified by education or experience to teach the course, or parts of a course, to which the instructor is assigned.

Any person with a four year college or graduate degree is qualified to teach any course in his or her field of study. Any state

certified fire protection system contractor with at least five years' experience may teach any technical course within the scope of the

contractor license held; however, no contractor whose license is suspended or revoked as a result of administrative action shall

teach or serve as a continuing education instructor. The Regulatory Licensing Section is not permitted to reject a course based upon

the proposed instructor, but is permitted to approve a course contingent on certification that all instructors meet those minimum

requirements before conducting the course and before advertising that the course is approved for continuing education credit.

(4) Written instructional materials and any audio-visual aids must provide instruction relevant to fire protection under Florida

law.

(5) The course or combination of courses shall be approved by the Regulatory Licensing Section. The Regulatory Licensing

Section shall approve any course, seminar, or conference in the technical areas provided by any university, community college,

vocational-technical center, public or private school, firm, association, person, corporation or entity which meets the criteria

provided in this rule.

(6) The number of contact hours assigned to any course shall be determined by the Regulatory Licensing Section based on the

course content and length of the course.

(a) Requests for approval shall be submitted on Form DI4-1239 (3/00), "Request for Approval of Fire Protection System

Contractor Continuing Education Coursework" as adopted and incorporated herein by reference.

(b) Forms are available from and submissions shall be sent to: Regulatory Licensing Section, 200 East Gaines Street,  
Tallahassee, Florida 32399-0342.

(c) Each certificateholder shall be notified by the Regulatory Licensing Section, in writing, if the coursework does not satisfy the continuing education requirement in Section 633.537, F.S. No notification will be given over the telephone.

- 87

(d) The application shall include the total number of classroom or interactive distance learning hours, the course syllabus, a detailed outline of the contents of the course, and the name and qualifications of all instructors. The Regulatory Licensing Section shall approve continuing education courses which appropriately relate to the technical skills required of fire protection contractors and contain sufficient educational content to improve the quality of the contractor's performance and are taught by qualified instructors. Continuing education coursework approval shall be valid for two years from the date of issue, provided that no substantial change is made in the approved coursework.

(e) The number of classroom hours must be devoted to course content and does not include registration periods, meals, and keynote speakers or similar nonsubstantive time periods.

(f) Examples of courses which will be approved if the criteria and procedures of this rule are met:

1. Florida Fire Sprinkler Association meetings;
2. American Fire Sprinkler Association meetings;
3. NFPA meetings and seminars; and
4. Training sessions conducted by manufacturers.

(g) The Regulatory Licensing Section shall approve continuing education courses within 90 days from the date of receipt. Such approval will be based upon the submission of coursework which relates to the technical skills of the fire protection system contractors and which contains educational content to improve the quality of work being performed.

(h) Each approved course will be assigned a course number and the course will be identified by course title as submitted and the number of continuing education hours awarded. A listing of approved courses will be available from the Regulatory Licensing Section. The course list will include the course number, the course title, the course submitter, and the type of course.

(i) Within 90 days of the conclusion of each approved course, the organization or person offering the course shall inform the Regulatory Licensing Section that the course was completed and shall supply the Regulatory Licensing Section with a sign-in sheet or roster. The sign-in sheet or roster shall contain:

1. The course name;
2. The course number;
3. The course provider;
4. The date the course was offered;
5. The duration of the course;
6. The contractor's name;
7. The contractor's license number;
8. The contractor's signature.

For interactive distance learning courses, in lieu of the original sign-in sheet required above, the course provider shall maintain and provide a record of the registration login, course access log, and course completion, which shall include the information required in

subparagraphs 1. through 7., above. In lieu of providing a document bearing the contractor's signature, the course provider shall provide the contractor's identity verification data which shall include the contractor's password and the contractor's mother's maiden name.

(j) Each person who completes an approved course shall be issued a certificate of completion by the course provider. The certificate of completion shall contain the name of the person who completed the course, the course provider's name, the course name as approved by the Regulatory Licensing Section, the course number, the date the course was taken, and the number of continuing education hours awarded for the course as approved for the course by the Regulatory Licensing Section. The course provider shall maintain a list of the names and license number of each person who completes each course conducted by the course provider for four years from the date of the course.

(7) Each certificateholder is responsible for attending the appropriate course or courses and for maintaining proof of completion of the course or courses. Such proof shall be in the form of copies of certificates of completion awarded. The Regulatory Licensing Section will not accept any proof of completion except that submitted in accordance with subsection (8) below.

(8) Prior to the annual expiration of the Certificate of Competency, the certificateholder shall submit proof of completion of the required course or courses to the Regulatory Licensing Section. Submissions shall be submitted on a "Fire Protection System Contractor Continuing Education Coursework" form, DI4-1240 (3/00) as adopted and incorporated herein by reference. Forms are available from and submissions shall be sent to: Regulatory Licensing Section, 200 East Gaines Street, Tallahassee, Florida 32399-0342. Each certificateholder will be notified by the Regulatory Licensing Section, in writing, if the coursework does not satisfy the continuing education requirement in Section 633.537, F.S. No notification will be given over the telephone.

(9) Any Fire Protection System Contractor who does not complete the continuing education requirement shall not have his or her certificate renewed. If the certificateholder is not renewed, the certificateholder shall perform no work for which a license is required. A certificateholder wishing to become licensed again shall meet the requirements of Section 633.521, F.S.

*Specific Authority 633.01, 633.517(1) FS. Law Implemented 633.521, 633.537 FS. History—New 10-2-96, Amended 6-18-97, 6-8-98, 11-21-01, Formerly 4A-46.017.*

## **PART II GENERAL PROVISIONS**

- 88

### **69A-46.025 Scope.**

The provisions of this part shall apply to the lay out, fabrication, installation, inspection, alteration, repair, or servicing on the fire protection systems.

*Specific Authority 633.01 FS. Law Implemented 633.021(2), (3), (4), (5), (7), (16), (20), 633.082, 633.541, 633.547, 633.551, 633.554 FS.*

*History—New 12-21-88, Formerly 4A-46.025.*

### **69A-46.030 Definitions.**

(1) For purposes of this part, the definitions in Rule 69A-46.005, F.A.C., shall have the same meaning as in Part I.

(2) In addition, the following term shall have the following meaning: “Registered professional engineer” shall mean an individual who is registered to engage in the practice of engineering as prescribed in Chapter 471, F.S. *Specific Authority 633.01 FS. Law Implemented 633.021 FS. History—New 12-21-88, Amended 8-1-90, Formerly 4A-46.030.*

**69A-46.035 Standards of the National Fire Protection Association to be Complied With.**

The following standards of the National Fire Protection Association which are adopted in Rule Chapter 69A-3, F.A.C., including

the editions as adopted therein, shall be complied with by all those holding certificates of competency as fire protection system

contractors pursuant to the provisions of Chapter 633, F.S.:

(1) NFPA 11, Standard for Low Expansion Foam.

(2) NFPA 11A, Standard for Medium and High Expansion Foam.

(3) NFPA 12, Standard on Carbon Dioxide Extinguishing Systems.

(4) NFPA 12A, Standard on Halon 1301 Fire Extinguishing Systems.

(5) NFPA 13, Standard for the Installation of Sprinkler Systems.

(6) NFPA 13D, Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes.

(7) NFPA 14, Standard for the Installation of Standpipe and Hose Systems.

(8) NFPA 15, Standard for Water Spray Fixed Systems for Fire Protection.

(9) NFPA 16, Standard for the Installation of Foam-Water Sprinkler Systems and Foam-Water Spray Systems.

(10) NFPA 17, Standard for Dry Chemical Extinguishing Systems.

(11) NFPA 17A, Standard on Wet Chemical Extinguishing Systems.

(12) NFPA 20, Standard for the Installation of Centrifugal Fire Pumps.

(13) NFPA 22, Standard for Water Tanks for Private Fire Protection.

(14) NFPA 24, Standard for the Installation of Private Fire Service Mains and Their Appurtenances.

(15) NFPA 72, National Fire Alarm Code.

(16) NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations. Section 7-2.2 of

NFPA 96 applies prospectively only. Existing installations are permitted to remain in place subject to the approval of the authority having jurisdiction.

(17) NFPA 214, Standard for Water Cooling Towers.

(18) NFPA 231D, Standard for Storage of Rubber Tires.

(19) NFPA 232, Standard for Protection of Records.

(20) NFPA 409, Standard on Aircraft Hangars.

(21) NFPA 13R, Standard for the Installation of Sprinkler Systems in Residential Occupancies up to and including four Stories in Height.

(22) NFPA 25, Standard for the inspection, testing, and maintenance of Water-based Fire Protection Systems, except that

quarterly flow tests will be required for those systems supplied by a municipal water supply.

(23) NFPA 2001, Standard on Clean Agent Fire Extinguishing Systems.

(24) NFPA 230, Standard on Fire Protection of Storage.

*Specific Authority 633.01 FS. Law Implemented 633.01, 633.065, 633.082 FS. History—New 12-21-88, Amended 7-19-89, 8-1-90, 10-20-93,*

*10-2-96, 6-8-98, 11-21-01, Formerly 4A-46.035.*

**69A-46.040 Installation Requirements for Automatic Sprinkler Systems Employing Water as the Extinguishing Agent.**

(1) Fire protection system contractors installing an automatic sprinkler system employing water as the extinguishing agent

shall supervise and be responsible for the complete system, except that a contractor installing the underground pipe shall supervise

and be responsible only for the portion he or she installs and the contractor installing the remaining portion of the system shall be responsible only for his or her portion of the work. The contractor shall be responsible to install the complete system in compliance with the National Fire Protection Association standards adopted pursuant to Rule Chapter 69A-3, F.A.C., except that if a contractor installs the underground pipe he or she shall be responsible for that portion of the system, and the Contractor installing the remaining portion shall be responsible for the system from the point of connection to the underground throughout the remainder of the system.

- 89

(2) The complete system begins at the point-of-service as defined in Section 633.021(16), F.S., and ends at the most remote head inside the facility.

(3) In order to ensure that sufficient water is available at the point-of-service to provide the water inside the facility as required by the plans, the contractor who installs the underground portion shall be responsible for conducting the acceptance tests required by NFPA 13 and shall personally, sign and maintain on file the Contractor's Material and Test Certificate for Underground Piping as specified in NFPA 13, as adopted in Rule Chapter 69A-3, F.A.C. If the above ground pipe is installed by a contractor other than the one who installed the underground, the contractor shall be responsible to obtain a copy of the underground certificate from the underground contractor and maintain it on file before connection to the underground is made. If the contractor is unable to obtain the certificate, the contractor shall notify the Regulatory Licensing Section.

(4) Upon completion of the final installation of the aboveground piping, the contractor shall conduct the tests and sign and maintain on file the Contractor's Material and Test Certificate for Aboveground Piping as specified in NFPA 13, as adopted in Rule 69A-46.035, F.A.C.

(5) Failure to complete and maintain the two certificates described in subsections (3) and (4) above shall be grounds for disciplinary action as violations of Section 633.539, F.S.

(6) The contractor whose name appears on the application for the building permit shall be responsible for the acceptance tests which are required in NFPA 13. The contractor shall complete all portions of the Contractor's Material and Test Certificate(s) that are related to the system being tested. The contractor shall sign and date the test certificates. In cases where there is no building permit, the contractor that supervised the installation shall be responsible for the performance of these duties.

(7) The contractor shall maintain on file all Contractor's Material and Test Certificates, and shall provide such to the State Fire Marshal upon his request.

(8) The contractor shall complete and attach to the system a tag as described in Rule 69A-46.041, F.A.C. *Specific Authority 633.01 FS. Law Implemented 553.79(6), 633.065, 633.539, 633.547(2)(e) FS. History--New 12-21-88, Amended 8-1-90, 10-20-93, 11-21-01, Formerly 4A-46.040.*

**69A-46.041 Inspection, Testing and Maintenance Requirements for Fire Protection Systems.**

The contractor I or II shall submit in writing to the Regulatory Licensing Section the names, addresses, and evidence of NFPA 25 training of all individuals in his or her employ that are performing inspections of fire protection systems. In addition, the licensed

contractor I or II shall submit a full face current color passport photograph of each inspector along with a copy of the inspector's current driver's license or identification card issued by the Florida Department of Highway Safety and Motor Vehicles. The contractor shall not allow any individual to perform inspections under his or her certificate until that individual has been listed with the Regulatory Licensing Section. The Regulatory Licensing Section shall issue a identification card to each inspector. The identification card is not a license. The contractor shall be responsible for each listed individual's inspections until he or she has requested in writing that the Regulatory Licensing Section delete the individual from his or her list of inspectors. The licensed fire protection system contractor shall notify the Regulatory Licensing Section, in writing, of an inspector leaving his or her employ within fifteen days of the termination. An inspector photo identification card of an individual leaving the employ of a contractor becomes void and inoperative on the date of departure.

(1) A Fire Protection Contractor, contracting to perform inspecting, testing, and maintenance service on a fire protection system shall comply with the requirements of the applicable NFPA standard as adopted in Rule Chapter 69A-3, F.A.C.

(2) Each system that has been inspected, tested, or maintained by a fire protection contractor, or his or her designated inspector, shall have a record tag of durable and weather resistant material placed on the riser or control device. The tag at "Figure A" shall include the following:

- (a) Name, address and contractor license number of company.
- (b) Date of inspection and type of inspection.
- (c) Inspected by \_\_\_\_\_.
- (d) The tag shall state "For more information see the inspection report."
- (e) The tag shall state "Do not remove by order of the State Fire Marshal."
- (f) The tag shall be approximately 3 1/2 inches by 5 1/2 inches.

(3) The contractor shall maintain in his or her file all records of any fire protection system having been serviced.

(4) These records shall be made available to the State Fire Marshal upon request.

(5) The contractor or the designated inspector shall complete in detail the inspection reports as required in NFPA 25, as adopted in Rule Chapter 69A-3, F.A.C., that outlines all points of the inspection, test, and maintenance as required by the applicable NFPA standards. A copy of which shall be provided to the owner at the completion of each inspection performed.

(6) The inspection report shall include detailed explanation of any deficiencies. The report shall indicate if the inspection is a weekly, monthly, quarterly or annual inspection. The inspection report shall include the name of the registered inspector, the inspector registration number, signature, the date and time of inspection, and the signature of the owner or the owner's representative.

**SEE FLORIDA ADMINISTRATIVE CODE FOR "FIGURE A"**

- 90

*Specific Authority 633.01 FS. Law Implemented 471.025, 553.79(6), 633.065, 633.547(2)(e) FS. History--New 10-20-93, Amended 11-21-01, Formerly 4A-46.041.*